

DRUMMOND AREA SCHOOL DISTRICT
SCHOOL ENERGY AND DEMAND REDUCTION OPPORTUNITY ASSESSMENT

JULY 25, 2019

Mr. Robert Drevlow

FACILITY: Drummond Area K-12 School

LOCATION: Drummond WI.

This material is based upon work supported by the by the Public Service Commission of Wisconsin, Office of Energy Innovation and the Department of Energy, Office of Energy Efficiency and Renewable Energy (EERE), under the State Energy Program Award Number DE-EE0000163." Agreement Number EIGP-18-10

Disclaimers

"This report was prepared as an account of work sponsored by an agency of the United States Government. Neither the United States Government nor any agency thereof, nor any of their employees, makes any warranty, express or implied, or assumes any legal liability or responsibility for the accuracy, completeness, or usefulness of any information, apparatus, product, or process disclosed, or represents that its use would not infringe privately owned rights. Reference herein to any specific commercial product, process, or service by trade name, trademark, manufacturer, or otherwise does not necessarily constitute or imply its endorsement, recommendation, or favoring by the United States Government or any agency thereof. The views and opinions of authors expressed herein do not necessarily state or reflect those of the United States Government or any agency thereof."

PURPOSE

Identify power and energy reductions that can reduce the school's utility bill and provide the basis for qualifying for a state sponsored "Energy Innovation Grant" that combines incentives for implementation of renewable energy sources with reductions in existing electricity use through improved equipment and operation.

PROCESS

A team representing the grant program consisting of Bill Bailey, Niels Wolter and myself met with Chris Vaillancourt, school facilities manager, toured the facility and discussed facility operations and observed existing spaces, equipment and significant energy using equipment and applications.

Bill Bailey provided general background of the solar component and background for the grant application, Niels Wolter explored and discussed potential mounting and interface opportunities for the solar application. I observed and commented on various energy application and energy reduction opportunities. Chris Vaillancourt provided information about the current facility conditions and current equipment and controls.

I reviewed the information acquired from the on-site assessment, made a preliminary assessment of items of interest and followed this with an additional meeting with Chris Vaillancourt to assess his and the perceived school district interests and limitations and to secure additional information needed to create useful decision-making models.

I prepared Xcel worksheet models to evaluate the energy and demand reduction potential, make recommendation for implementation and rudimentary simple payback period estimates.

Chris Vaillancourt provided a multiyear utility bill summary showing monthly and annual energy use, demand components and expenses. He also provided a total lamp count for several major areas in the school, as well as other valuable information relative to equipment and operating practices.

APPLICATIONS REVIEWED

Opportunities for power and energy reductions in the following areas were explored.

1. Lighting
2. Heating system circulation pumps
3. Air handlers
4. Univents

It is noted that only electric energy reduction opportunities were reviewed but that significant fuel reduction opportunities also exist.

It is also noted that air conditioning equipment electricity reduction opportunities have not been evaluated at this time.

GENERAL INFORMATION

The facility is a K-12 school building constructed over many years with the most recent construction occurring in 1986, 1992 and 2000.

The facility's total area is approximately 100,000 square feet, is totally utilized and include 2 gyms, a large commons/cafeteria. Classrooms, mechanical skills workshop area, food service area and equipment rooms, administration offices and board room areas and various storage and mechanical equipment areas.

The facility is light and airy in most areas. The facility does not appear overcrowded, and appears well maintained.

The annual electric energy expense for the facility was \$47,343 for a 12-month period in 2018-2019 and the maximum peak monthly billing demand was 175kw. The annual energy consumption was 442,000 kwh. for the same period. The minimum monthly demand was 86 kW occurring in the summer, non-school session, period. The effective annual rate for all electric energy used is \$0.107 per kWh. The facility is served by Xcel Energy on a time of use rate structure.

The boiler and circulation pump systems are high performance and were very recently replaced.

The lighting system is T-8 lamp based throughout. The existing lamps and ballasts are reported to have been installed in 2010 but the troffers appear to date to the building's original construction dates.

Control systems are limited. Direct Digital Control (DDC), i.e., Metasys control, is provided for the 2000 construction only and currently does not provide visual access to control graphics or control due to a software issue. This limitation is expected to be resolved by June 30, 2019. The older parts of the facility are served by pneumatic controlled air handlers and independently controlled univents.

Food service exhaust fans exist but are reported to be used minimally.

Computer and information technology exist but was not reviewed.

Exterior lighting was not reviewed.

SUMMARY OF ASESSMENTS

1. Lighting

Lighting is the facility's largest installed energy use application and therefore presents a significant energy and demand reduction opportunity if appropriate cost-effective measures can be identified and implemented.

Light energy reduction can be achieved in several ways.

- Light level reductions, including: delamping, low watt lamp and ballast replacement, and control
- Light hour use reductions
- More efficient lighting equipment, including lamp replacement and fixture replacement
- Combinations of the above

Light Level Reductions

It was noted in touring the facility that lighting levels (lumen values) varied significantly across the facility. Lighting levels appeared to vary for apparently similar applications at different locations in the school. This suggests that some of the areas are "over lit" and a reduction in light levels could be implemented to reduce energy, demand and expenses.

It was also observed that several instructors had taken steps to reduce the lighting levels in their classrooms by applying films over the lighting troffers to reduce the light levels to what they considered a more appropriate level.

It was also noted that various gym lighting levels were available through switching but hardly ever used by the staff. This suggests that light level reductions are desired and being achieved but the school is not gaining any corresponding reduction in energy use or cost.

It is also noted that current instructional processes utilize personal computer screens and smartboards more and pages and paper less. Higher lighting levels result in higher glare levels for personal screen use and less contrast for smart boards and other front screen applications. Light level reductions may result in light levels more compatible for current instructional methods.

The T-8 troffers used throughout the classrooms, halls and large space areas are all lensed troffers. The current troffers observed appear to be troffers from the original construction dates but have been upgraded to T-8 lamps and electronic ballasts reported to be 2010.

Lighting control is limited to manual wall switching. Two switches exist in many classrooms and can switch 2 independent circuits but it does not appear that these are being applied in

any consistent way to reduce energy and demand. it is also not known how the circuits allocate the light in the classrooms.

Light level reductions should be based on an evaluation of current and proposed light level requirements for the activity and or instruction occurring in the lighting zone. The overall aesthetic impact of the light levels and the desires of the primary occupants of the space also need to be considered. The probability of the space light level requirements changing over time due to activity, instructional or personnel changes also needs to be considered.

The primary tool in this process is a “light meter ”, which measures the lumen /lux values at any point the light meter is held. This measures the input of all light sources. Thus, the impact of a reduction of a single light source may only result in a fractional reduction of the light total light level.

Light level recommendations are available from many sources including Focus on Energy, lighting providers, engineers etc. The final decision however needs to be made by the school administration based on their needs and desired final out comes.

There are several means of reducing light levels:

Delamping

Delamping is a low cost but effective means of reducing light output from a troffer or fixture to reduce power and energy requirements. Light power reduction by removing a lamp from a fixture will be generally proportional but somewhat less than the number of lamps removed to the total lamps in the troffer. E.g., removing 1 lamp from a 4-lamp troffer may result in a 20 % power and lighting reduction.

Removing a lamp from a fixture reduces the heat generated in the troffer and marginally increases lamp life of the remaining lamps thereby reducing the cooling load for the space and allowing the heating load to be supplied by a lower cost heat source.

Delamping results in a change in the appearance of the troffer lens itself. The light intensity will be reduced in the area the lamps were removed.

Lamp and troffers experience light depreciation with age i.e. light levels gradually decay. Lamp replacement of the remaining lamps and thorough cleaning of the troffer and lens will offset much of the light output reduction caused by the lamp removal.

Low Watt Lamp and Ballast Replacements

Reductions in power input and light output of a troffer can also be achieved by replacing the current lamps and or ballasts with available lower power and output replacements. 25-watt 4 ft florescent tubes are available to replacement existing 32- or 40-watt tubes. Low ballast factor ballasts are also available which cause a power and light reduction from the lamps served.

Although these opportunities exist for any area where light level reductions are considered appropriate, this measure has in general been superseded by conversion to L.E.D. lamps and or fixtures.

Controls

The time-honored method for light reduction has been and remains “turning some of the light sources off”. The historic manual methods of achieving this, however, have proven ineffective in many applications due to a lack of motivation, understanding or discipline of the appropriate “switch person”.

Dimming is an effective light and power reduction technique but not easily implemented or cost effectively applied to T-8 florescent lamps (the current lighting system in this facility). Dimming is however readily accomplished with many of the current L.E.D. (light emitting diode) lamps and troffers. Dimming can be implemented based on instructional needs, schedules, or total light levels in the space (e.g., responding to varying levels of window-sourced daylight).

Partial lamp shutdown techniques are available but relatively expensive to implement and require multiple circuits and switching or controls, which, as previously indicated, do not currently exist for the entire facility.

In general dimming is preferable to partial lamp switching as a light level reduction technique.

Light Hour Reductions

Light energy and expense are directly related to the operating time of the lamps. Occupancy controls can turn off lights in areas where no occupant need for light exists. Photo sensor controls allow entry ways, foyers and other areas experiencing significant daylight introduction through windows or skylights to turn off the interior lights at desired total light levels. Electronic time clocks or DDC system control can provide effective precise lighting applications and curtail light use when not required.

More Efficient Lighting Equipment

Recent technological improvements and manufacturing efficiencies have made L.E.D. lighting products cost effective upgrade opportunities for T-8 troffers. L.E.D. products have been used for many years for specialty applications including exit lighting, traffic lighting and signage.

More recently, however, the range of cost-effective applications for L.E.D. lighting products has expanded to include the general lighting applications for common school facility

applications. The efficiency of the L.E.D. technology can be applied in several ways and provide some alternatives for reducing light power and energy.

Lamp Replacement

The current 4 ft T-8 lamps provide light output initially at approx. 90 lumens per watt. Over time this deteriorates by 20% to 30%. 4 ft. L.E.D. tubes are currently available that provide up to 2200 lumens at approximately 125 lumens per watt.

The light output of the L.E.D. tubes depreciates very little over the life of the tube and the tube life expectancy is much longer than a florescent lamp. This means that the light level remains more constant over the life of the lamp and less excess has to be applied initially to assure appropriate light levels at the end of lamp life. Thus, a lower initial light level can be applied which reduces power and energy for the entire lamp life.

The maximum light output from the 4 ft. L.E.D. tubes however is less than the initial output of approximately 2900 lumens from a new T-8 lamp and represents a significant reduction depending on the existing and proposed equipment and needs to be considered in the application.

Where the reduced light level is acceptable, this measure results in significant energy and power reductions and typically can be installed by in house staff.

The reduced power input to the L.E.D lamp also reduces the heat generated in the troffer which results in reduced cooling load for the space and reduced heating energy cost.

The L.E.D. lamps are available as dimmable units if controls are applied. The L.E.D. tubes are available in "bypass units" which allow removal of the existing ballast if desired or "direct connect" which retain the existing ballast.

Fixture Replacement

It has been noted that the majority of the facility lighting is lensed troffers. Lensed troffers of the era of the existing lighting had efficiencies of approx. 70% this means that approximately 30 % of the light generated by the lamps doesn't make it out of the troffer. This light loss also increases with time due to dirt accumulation and deterioration of the lens material.

Current troffer design without lenses achieve higher efficiencies by design. Use of lamps in the existing troffers means that light is equally radiated from all portions of the circular tube and a reflector is required to redirect the light radiated from the upper portions of the tube down into the lighting zone. This results in light loss and eventual light level depreciation. The L.E.D. tubes are directional and don't require reflectors to place the light output into the desired area. This allows a more efficient application than T-8 lamp type application. Reflectors are still provided however in many efficient fixtures to provide indirect lighting to reduce glare.

Fixture selection needs to consider the application. The L.E.D. fixtures are also dimmable and controllable but require additional sensors and or controls.

Combination of the Above

It should seem obvious that the maximum demand and energy reduction potential would lie in a careful light reduction effort followed by or incorporated with implementation of more efficient and effective lighting apparatus responding to effective control mechanisms.

To that end the L.E.D. fixture applications with associated controls and applied to the considered appropriate light levels represents the maximum reduction opportunity consistent with adequate, appropriate and aesthetic light application.

Lighting Evaluation

In consideration of the previous discussion I prepared excel worksheets modeling the estimated impact of several of the scenarios described. The models represent the energy, demand and expense reductions likely to occur based on the lamps estimated operating hours, number of lamps, utility rates and estimated implementation expenses. All of the variables are available for revision by the facility management and the revised work sheets will show the impact of the revision. The number of lamps involved in all models is based on the current total lamps by area as provided by Chris Vaillancourt.

The following lighting models were developed:

Delamping: Removing lamps from areas that have higher than required or desired lighting levels throughout the facility. The major delamping is anticipated to occur in classrooms where shading is currently applied, hallways where activity-based lighting requirements are low and the elementary gym. Effective delamping requires that a light level assessment be made prior to delamping. The only significant expense beyond in-house labor is lamp disposal for lamps physically removed from the troffers. Note: it is not necessary to remove either lamps from the troffers but is recommended.

Lamp replacement: Replacing current 32-watt t-8 lamps with L.E.D. tubes which fit easily into the existing troffers. Although this is expected to provide adequate and appropriate light levels throughout the premise in most applications, there may be some areas where the lighting targets are not met by the currently available L.E.D tubes and replacements will not be possible. The number of potential replacements will hinge on the light study. Thorough reflector and lens cleaning is recommended at this time.

Fixture replacement: Replacing existing troffers with high performance, dimmable L.E.D sourced indirect unlensed troffers. Again it is presumed that not all applications will allow

simple replacement. Some applications may require higher output or additional troffers to achieve the lighting goals.

2. Heating System Circulation Pumps

The heating system hot water from the boilers is circulated throughout the facility by 2 ABB variable speed drive-controlled pumps. The pumps appear to be controlled by a differential pressure control at the system supply and return headers adjacent to the pumps. The pumps appear to be operating in a sequential scenario. As observed, the lead pump was running at a much higher speed than the secondary pump. I believe that the pumps were designed to provide redundant service which provides continuing operation upon failure of one of the pumps. This scenario however provides twice the design capacity required even during peak load periods.

The current operating scenario is expected to provide the pressure needed to supply any of the radiation devices on the system with adequate flow to achieve the rated heat output with essentially all of the radiation devices calling for rated heat output.

This control scenario provides more pressure and uses more power than required for most if not all of the operating hours due to the fact that the design loads typically are greater than any realized heating loads. A more effective control strategy would provide only the pressure required for the heating loads currently being experienced. There are several control options to consider. A frequently used option is to monitor and control the pressure required at the most remote radiation device on the system. The laws of physics relating to pump operations (pump laws) indicate that operating 2 pumps in parallel results in lower total power requirements and less energy than a sequential operation as is currently in use. This scenario will be effective for the upper operating range of operations. An investigation is required to determine at which speed point the parallel operation should begin. At the lower load range, single pump operation at low speed will result in the lowest total power use.

Additional pump power and reductions are available by adding an "unoccupied mode setback" control, and "warm weather shutdown" controls for both occupied and unoccupied mode operations. The "unoccupied mode setback" control recognizes that less pressure and flow are required for the reduced unoccupied period loads during, nights, weekends and holidays, and reduces the pressure setpoint and thereby the power and energy used.

The "warm weather shut down" control recognizes that at some temperature conditions, heating is no longer needed in the facility and shuts the pumps off. This control reduces the pumping requirements but also eliminates the flow of heated water throughout the system which provides inadvertent, and undesirable, heating of the facility. The Boiler system includes

an option for warm weather shut down but is not currently operational. Boiler and pump system controls need to be coordinated but both can be effectively utilized.

Although providing the enhanced pump system controls may be accomplished independently at the VFD control. Providing the enhanced controls through the DDC control system will allow remote monitoring and a wider range of control operations and integrations with other operating systems. An Excel model was prepared for this opportunity.

3. Air Handlers

The largest air handler in the facility serves the auditorium. It is equipped with a cooling system.

The unit is reported to operate in a temperature maintenance mode for most of the year. The auditorium space is sparsely occupied for all school session days and only sees occupancy levels requiring full capacity operation during performances. It also has a summer operating requirement that includes cooling but again the space has low occupancy levels except for performance periods. These conditions are in many respects, similar to gym operations and can be effectively served by a "large space" control configuration that utilizes variable speed fan control to reduce fan power and energy for the low occupancy time periods while maintaining set point temp and adequate ventilation. The system can be operated as a single zone variable flow application. Continuous operation at low speeds or at variable but low speeds requires less energy than intermittent operation, eliminates the whine and associated strain on belts and bearings associated with startups and operates at a much lower and less objectionable noise level than full speed intermittent operation. The low speed continuous operation also allows more effective operation of the associated cooling system. This unit is currently controlled by the DDC system and would allow the addition of additional control features at minimum expense. An Excel model was prepared to analyze this opportunity.

4 small air handlers exist in the facility. They service several areas in the facility and are controlled by a Metasys pneumatic control system.

These units are not variable speed control. The units serve music rooms and a gym which are both characterized as "large spaces" having predominantly low occupancies with intermittent periods of higher occupancies. These air handlers will respond to variable speed operation and reduced power and energy use when equipped with variable speed drives and DDC control. An excel model was prepared for this opportunity.

4. Univents

Many of the classrooms have the heating, ventilation and air circulation needs served by Trane Univents.

These units are reported to have variable speed motors and originally were able to modulate fan speed in response to heat requirements. Over time a significant share of these units have lost modulating capacity and operate as on or off units only. Their continuous modulating speed operations will use less power and energy than intermittent full speed operation.

It is noted, that the current intermittent operation of the failing units does not meet the state code and ASHRAE recommendations for continuous ventilation in classroom spaces.

Although power and energy reductions are anticipated, with the restoration of the variable speed operating capability of all of the classroom units, restoring the continuous ventilation capability appears to be the more compelling motivation for implementing variable speed operation restoration to these units. An Excel model of this opportunity was prepared.

Results

Table 1. Summary of the Energy Efficiency Opportunities to Reduce Energy Costs at the Drummond School. Note that payback periods do not include available incentives (such as from Focus on Energy).

	Energy Savings (kWh)	Energy Savings (\$)	Demand Reduction (kW)	Monthly Demand Savings (\$)	Distribution Demand Savings (\$)	Annual Bill Savings (\$)	Cost of Measure (\$)	Payback Period (Years)
Lighting Options								
1. Delamping	38,468	\$ 2,654	16	\$ 1,925	\$ 231	\$ 4,810	\$ 269	0.06
2. LED Relamping	64,895	\$ 4,475	29	\$ 3,332	\$ 332	\$ 8,139	\$ 16,944	2.1
3. Troffer Replacement	94,282	\$ 6,420	39	\$ 4,572	\$ 531	\$ 11,523	\$ 61,596	5.4
Other Measures								
Auditorium Overhead Can LEDs	2,906	\$ 191	3	\$ 76	\$ 4	\$ 273	\$ 600	2.2
Auditorium Side Mount Flood LED Lamps	3,563	\$ 235	2.4	\$ 78	\$ 4.00	\$ 317	\$ 75	0.24
Hot Water Circulation Pump Controls	28,846	\$ 2,012	4	\$ 552	\$ 89	\$ 2,653	\$ 5,000	1.9
Auditorium Air Handler	17,611	\$ 1,189	7.5	223	45	\$ 1,467	\$ 7,000	4.8
Four Small Air Handler VFDS Control	4,197	\$ 277	3	\$ 155	\$ 20	\$ 452	\$ 6,000	13
Maximum Opportunity	151,405	\$ 10,324	59			\$ 16,685	\$ 80,271	5
Includes the Troffer Replacement								
Annual Energy, Demand and Bill Savings	34%		34%			35%		
Based on 2018-2019 Billing								

All of the lighting opportunities modeled and evaluated appear to be effective in reducing power and energy and result in simple payback periods well within the life expectancy of the application. The troffer replacement option provides the most power and energy reduction opportunity but does not yield as early a payback as the other options given that extended equipment life and improved lighting environments are not considered.

The small air handler VFD and control measure does not appear to be available without an expansion of the DDC controls to include these units. The addition of the DDC control upgrade to this measure results in a very long payback period.

All of the additional opportunities evaluated also appear to be effective in reducing power and energy use in the facility and simple paybacks are within the life of the application with the exception of the Uninvent repair. However, as previously noted power and energy reduction should not be the primary motivation for implementing this opportunity.

The simple payback assessments do not recognize the value of extended system life or improved instructional environments. They do however provide a key element for more sophisticated evaluations which include unique school administrative inputs and perspectives.

The estimated power and energy reduction values of each measure modeled as well as the totals and associated paybacks are shown on a summary worksheet. The individual opportunity worksheets are also available for revision and confirmation of input parameters and

applications. It is noted that all cost information is based on estimates only and no “proposals” for any opportunity implementation were collected.

RECOMMENDATIONS

- Recommended - Lighting Study: To achieve the maximum electric power and energy reduction possible, a lighting study is recommended to determine the desired but minimum acceptable light levels for all areas served by T-8 troffers followed by installation of high performance, indirect L.E.D. troffers with dimming control and associated controls appropriate for the application wherever possible.
- Recommended - DDC Control Hot Water System: Implementation of DDC control for the hot water heating circulation pumps with application of parallel pump control, load reset warm weather shutdown and occupied, and unoccupied setback is recommended.
- Recommended - DDC Control Auditorium: Installation of a variable speed drive and control for the auditorium and with DDC control application as a single zone variable air volume application.
- Recommended: Upgrading Pneumatic System Control for the 4 Small Air Handlers: Consider upgrading the pneumatic system control for the 4 small air handlers with the implementation of VFDs and associated large space management controls upon completion of the DDC improvements.
- Install a datalogger, like an eGauge, to monitor moment-by-moment electrical consumption. A basic unit would cost \$700-\$800 and a more detailed logger would add about \$35/current transformer. This data would be useful for future energy efficiency analysis and could be coupled with solar generation analysis. They are easily ordered online and installed by any electrician.

Annex 1. Delamping and Conversion of t-8 lamps to LED, Data, Assumptions and Analysis.

SCHOOL LIGHTING ASSESSMENT		R.A.DREVLLOW
OPTION A	DELAMPING	
	REMOVE ONE OR MORE T-8 4 FT LAMPS FROM EACH ELECTRONICALLY BALLASTED 2X2 TROFFER WHERE THE REDUCED LIGHT LEVEL IS DEEMED DESIREABLE OR ADEQUATE AND APPROPRIATE FOR INSTRUCTIONAL, ACTIVITY AND AESTHETIC REQUIREMENTS.	
BENEFIT	A	POWER DEMAND AND ENERGY COST REDUCTION
	B	ACHIEVE DESIRED LIGHT LEVELS CURRENTLY ACHIEVED BY SHADING OF TROFFERS
	C	TRANSFER ASSOCIATED HEATING TO A LOWER COST FUEL
	D	REDUCE COOLING LOAD WHEN COOLING IS DESIRED
	E	ZERO INVESTMENT EXPENSE IF DONE IN BY IN HOUSE STAFF
	F	MARGINALLY IMPROVES LUMINAIRE EFFICIENCY
	G	PROCESS CAN BE REVERSED AT NO EXPENSE IF APPLICATIONS CHANGE OR LIGHTING TARGET CHANGES
DOWN SIDES		
	A	LESS POWER AND DEMAND REDUCTION POTENTIAL THAN OTHER OPTIONS
	B	REDUCTION IN UNIFORM LIGHT DISTRIBUTION FROM TROFFERS
	C.	NOT COMPATIBLE WITH DIMMING OPTIONS

SCHOOL WIDE LAMP TOTAL			LIBRARY CAFETERIA HALLWAYS ETC	MUSIC TECH MIDDLE SCH HALLWAYS	UPSTAIRS	H.S. GYM	
AREA		ELEMENTARY					TOTAL
LAMPS		597	959	844	634	146	3180
DELAMP POTENTIAL		20%	25%	10%	15%	0%	17%
LAMPS		119	240	84	95	0	539
LAMP WATTAGE		30	30	30	30	30	
TOTAL KW REDUCTION		3.6	7.2	2.5	2.9	0.0	16.2
AVE MO FACILITY DEMAND		135.0	135.0	135.0	135.0	135.0	135.0
% REDUCTION		3%	5%	2%	2%	0%	12%
EST. AVE ANNUAL OPERATING HOURS		2200	2500	2500	2200	3000	
ESTIMATED ANNUAL KWH REDUCTION		7880.4	17981.25	6330	6276.6	0	38468.25
TOTAL FACILITY KWH USE		450000	450000	450000	450000	450000	450000
REDUCTION %		1.8%	4.0%	1.4%	1.4%	0.0%	8.5%
CURRENT ON PEAK KWH RATE		\$ 0.075	\$ 0.075	\$ 0.075	\$ 0.075	\$ 0.075	
CURRENT OFF PEAK KWH RATE		\$ 0.045	\$ 0.045	\$ 0.045	\$ 0.045	\$ 0.045	
EST ON PEAK USE		0.8	0.8	0.8	0.8	0.8	
EFFECTIVE RATE		\$ 0.07	\$ 0.07	\$ 0.07	\$ 0.07	\$ 0.07	
EST.ANNUAL ENERGY COST REDUCTION		\$ 543.75	\$ 1,240.71	\$436.77	\$433.09	\$ -	\$2,654.31
CURRENT MO DEMAND RATE ,PER KWPER MO		\$ 11.00	\$ 11.00	\$ 11.00	\$ 11.00	\$ 11.00	
EST AVE DEMAND		0.9	0.9	0.9	0.9	0.9	
COINCIDENCE FACTOR							
EST ANNUAL DEMAND CHARGE REDUCTION		\$ 428	\$ 855	\$ 297	\$ 345	\$ -	\$ 1,925
DIST DEMAND		0.95	0.95	0.95	0.95	0.95	
COINCIDENCE							
CURRENT DIST DEMAND RATE (PER KWPER MO)		1.25	1.25	1.25	1.25	1.25	
EST ANNUAL DIST DEMAND CHARGE REDUCTION		\$ 51	\$ 103	\$ 36	\$ 41	\$ -	\$ 231
EST TOTAL POWER AND ENERGY EXPENSE REDUCTION		\$ 1,023	\$ 2,199	\$ 769	\$ 819	\$ -	\$ 4,810
EST LAMP DISPOSAL EXPENSE PER LAMP		\$ 0.50	\$ 0.50	\$ 0.50	\$ 0.50	\$ 0.50	
EST TOTAL DISP[OSAL EXPENSE		\$ 59.50	\$ 120.00	\$ 42.00	\$ 47.50	\$ -	\$ 269.00
EST SIMPLE PAYBACK OF EXPENSE		0.06	0.05	0.05	0.06	#DIV/0!	0.06

Annex 2. LED Relamping Data, Assumptions and Analysis.

SCHOOL LIGHTING ASSESSMENT		R.A.DREVLOW
OPTION A	RELAMP WITH 4 FT HIGH PERFORMANCE,HIGH OUTPUT LED LAMPS	
	REPLACE EXISTING T-8 LAMPS ADEQUATE FOR THE LIGHTING REQUIREMENTS OF THE AREA WITH 4 FT LED TUBES.	
BENEFIT	A	ACHIEVES POWER AND ENERGY REDUCTION FOR THE ENTIRE FIXTURE LOAD
	B	ACHIEVE DESIRED LIGHT LEVELS CURRENTLY ACHIEVED BY SHADING OF TROFFERS
	C	TRANSFER ASSOCIATED HEATING TO A LOWER COST FUEL
	D	REDUCE COOLING LOAD WHEN COOLING IS MORE THAN DELAMPING
	E	MODEST INVESTMENT EXPENSE IF DONE BY IN HOUSE STAFF
	F	MARGINALLY IMPROVES LUMINAIRE EFFICIENCY
	G	ADDITIONAL LAMPS CAN BE ADDED IF FULL COMPLEMENT WAS NOT INITIALLY APPLIED OR ZONE USE CHANGES .
	H	LAMPS CAN BE REMOVED IF LIGHT LEVEL IS DEEMED EXCESSIVE
	I	LED TUBES MAY BE DIMMABLE FOR ADDITIONAL CONTROL
	J.	VERY LONG LAMP AND TROFFER LIFE EXTENSION.
DOWN SIDES		
	A	LUMEN DEPRECIATION OF AGED REFLECTORS AND LENSES REMAIN
	B	REDUCTION IN UNIFORM LIGHT DISTRIBUTION FROM TROFFERS WILL BE INCURRED IF LESS THAN FULL COMPLEMENT OF LAMPS IS USED

				LIBRARY	MUSIC	UPSTAIRS	H.S. GYM	
SCHOOL WIDE LAMP TOTAL				CAFETERIA	TECH			
				HALLWAYS	MIDDLE SCH			
AREA		ELEMENTARY	ETC	HALLWAYS				TOTAL
LAMPS		597	959	844	634	146		3180
LAMP CONVERSION		80%	75%	80%	75%	50%		17%
LAMPS		478	719	675	476	73		
EXISTING LAMP WATTS		30	30	30	30	30		
PROPOSED LAMP WATTS		18	18	18	18	18		
REDUCTION (KWPERLAMP)		0.012	0.012	0.012	0.012	0.012		
TOTAL KW REDUCTION		5.7	8.6	8.1	5.7	0.876		29
AVE MO FACILITY DEMAND		135.0	135.0	135.0	135.0	135.0		135.0
% REDUCTION		4%	6%	6%	4%	1%		22%
EST. AVE ANNUAL		2200	2500	2500	2200	3000		
OPERATING HOURS								
ESTIMATED ANNUAL		7880	21578	20256	12553	2628		64895
KWH REDUCTION								
TOTAL FACILITY KWH USE		450000	450000	450000	450000	450000		450000
REDUCTION %		1.8%	4.8%	4.5%	2.8%	0.6%		14.4%
CURRENT ONPEAK KWH RATE	\$	0.075	\$ 0.075	\$ 0.075	\$ 0.075	\$ 0.075		
CURRENT OFFPEAK KWH RATE	\$	0.045	\$ 0.045	\$ 0.045	\$ 0.045	\$ 0.045		
EST % ON PEAK		80%	75%	75%	80%	80%		
EST AVE EFFECTIVE RATE	\$	0.069	\$ 0.068	\$ 0.068	\$ 0.069	\$ 0.069		
EST. ANNUAL ENERGY COST	\$	544	\$ 1,456	\$ 1,367	\$ 866	\$ 181		\$ 4,415
MO DEMAND RATE	\$	11.00	\$ 11.00	\$ 11.00	\$ 11.00	\$ 11.00		
PER KWPER MO								
MONTHLY COINCIDENCE		0.9	0.9	0.8	0.9	0.8		
FACTOR								
MO DIST RATE	\$	1.25	\$ 1.25	\$ 1.25	\$ 1.25	\$ 1.25		
PER KWPER MO								
MO COINCIDENCE		0.9	0.9	0.9	0.9	0.9		
FACTOR								
EST.ANNUAL MO. DEMAND	\$	681	\$ 1,025	\$ 856	\$ 678	\$ 93		\$ 3,332
EST.ANNUAL DIST DEMAND	\$	77.37	\$ 116.52	\$109.38	\$ 77.03	\$ 11.83		\$ 392.13
EST TOTAL POWER AND	\$	1,302	\$ 2,598	\$ 2,332	\$ 1,621	\$ 286		\$ 8,139
ENERGY COST								
EST. PER LAMP COST	\$	6.00	\$ 6.00	\$ 6.00	\$ 6.00	\$ 6.00		
EST TOTAL LAMP EXPENSE	\$	2,866	\$ 4,316	\$ 4,051	\$ 2,853	\$ 438		\$ 14,523
EST. LAMP AND BALLAST	\$	1.00	\$ 1.00	\$ 1.00	\$ 1.00	\$ 1.00		
DISPOSAL EXP.PER LAMP								
EST.TOTAL DISPOSAL	\$	478	\$ 719	\$ 675	\$ 476	\$ 73		\$ 2,421
EXPENSE								
EST. TOTAL EXPENSE	\$	3,343	\$ 5,035	\$ 4,726	\$ 3,329	\$ 511		\$ 16,944
ESTIMATE SIMPLE PAYBACK		2.6	1.9	2.0	2.1	1.8		2.1
EXPENSE ONLY (YEARS)								

Annex 3. Troffer Replacement Data, Assumptions and Analysis.

SCHOOL LIGHTING ASSESSMENT		R.A.DREVLOW	
OPTION A		REPLACE EXISTING TROFFERS WITH HI PERFORMANCE INDIRECT HIGH OUTPUT TROFFERS.	
BENEFIT	A	ACHIEVES POWER AND ENERGY REDUCTION FOR THE ENTIRE FIXTURE LOAD	
	B	ACHIEVE DESIRED LIGHT LEVELS CURRENTLY ACHIEVED BY SHADING OF TROFFERS	
	C	TRANSFER ASSOCIATED HEATING TO A LOWER COST FUEL	
	D	REDUCE COOLING LOAD WHEN COOLING IS MORE THAN DELAMPING	
	E	MODEST INVESTMENT EXPENSE IF DONE BY IN HOUSE STAFF	
	F	MARGINALLY IMPROVES LUMINAIRE EFFICIENCY	
	G	ADDITIONAL LAMPS CAN BE ADDED IF FULL COMPLEMENT WAS NOT INITIALLY APPLIED OR ZONE USE CHANGES .	
	H	LAMPS CAN BE REMOVED IF LIGHT LEVEL IS DEEMED EXCESSIVE	
	I	LED TUBES MAY BE DIMMABLE FOR ADDITIONAL CONTROL	
	J.	VERY LONG LAMP AND TROFFER LIFE EXTENSION.	
DOWN SIDES			
	A	LUMEN DEPRECIATION OF AGED REFLECTORS AND LENSES REMAIN	
	B	REDUCTION IN UNIFORM LIGHT DISTRIBUTION FROM TROFFERS	
		WILL BE INCURRED IF LESS THAN FULL COMPLEMENT OF LAMPS IS USED	

SCHOOL WIDE LAMP TOTAL			LIBRARY	MUSIC	UPSTAIRS	H.S. GYM	
			CAFETERIA	TECH			
			HALLWAYS	MIDDLE SCH			
AREA		ELEMENTARY	ETC	HALLWAYS			TOTAL
LAMPS		597	959	844	634	146	3180
LAMP CONVERSION		80%	75%	80%	75%	50%	17%
TROFFERS		119	180	169	119	18	
EXISTING TROFFER WATTS		120	120	120	120	120	
PROPOSED TROFFER WATTS		55	55	55	55	55	
REDUCTION (KWPERLAMP)		0.065	0.065	0.065	0.065	0.065	
TOTAL KW REDUCTION		7.8	11.7	11.0	7.7	1.2	39
AVE MO FACILITY DEMAND		135.0	135.0	135.0	135.0	135.0	135.0
% REDUCTION		6%	9%	8%	6%	1%	29%
EST. AVE ANNUAL		2200	2500	2500	2200	3000	
OPERATING HOURS							
ESTIMATED ANNUAL		17074	29220	27430	16999	3559	94282
KWH REDUCTION							
TOTAL FACILITY KWH USE		450000	450000	450000	450000	450000	450000
REDUCTION %		3.8%	6.5%	6.1%	3.8%	0.8%	21.0%
CURRENT ONPEAK KWH RATE	\$	0.075	\$ 0.075	\$ 0.075	\$ 0.075	\$ 0.075	
CURRENT OFFPEAK KWH RATE	\$	0.045	\$ 0.045	\$ 0.045	\$ 0.045	\$ 0.045	
EST % ON PEAK		80%	75%	75%	80%	80%	
EST AVE EFFECTIVE RATE	\$	0.069	\$ 0.068	\$ 0.068	\$ 0.069	\$ 0.069	
EST. ANNUAL ENERGY COST	\$	1,178	\$ 1,972	\$ 1,852	\$ 1,173	\$ 246	\$ 6,420
MO DEMAND RATE	\$	11.00	\$ 11.00	\$ 11.00	\$ 11.00	\$ 11.00	
PER KWPER MO							
MONTHLY COINCIDENCE		0.9	0.9	0.8	0.9	0.8	
FACTOR							
MO DIST RATE	\$	1.25	\$ 1.25	\$ 1.25	\$ 1.25	\$ 1.25	
PER KWPER MO							
MO COINCIDENCE		0.9	0.9	0.9	0.9	0.9	
FACTOR							
EST.ANNUAL MO. DEMAND	\$	922	\$ 1,389	\$ 1,159	\$ 918	\$ 125	\$ 4,512
EST.ANNUAL DIST DEMAND	\$	104.77	\$ 157.79	\$ 148.12	\$ 104.31	\$ 16.01	\$ 531
EST TOTAL POWER AND	\$	2,205	\$ 3,519	\$ 3,158	\$ 2,195	\$ 387	\$ 11,464
ENERGY COST							
EST. PER TROFFER COST	\$	100.00	\$ 100.00	\$ 100.00	\$ 100.00	\$ 100.00	
EST TOTAL TROFFER EXPENSE	\$	11,940	\$ 17,981	\$ 16,880	\$ 11,888	\$ 1,825	\$ 60,514
EST. LAMP AND BALLAST	\$	5.00	\$ 1.00	\$ 1.00	\$ 1.00	\$ 1.00	
DISPOSAL EXP.PER LAMP							
EST.TOTAL DISPOSAL	\$	597	\$ 180	\$ 169	\$ 119	\$ 18	\$ 1,083
EXPENSE							
EST. TOTAL EXPENSE	\$	12,537	\$ 18,161	\$ 17,049	\$ 12,006	\$ 1,843	\$ 61,596
ESTIMATE SIMPLE PAYBACK		5.7	5.2	5.4	5.5	4.8	5.4
EXPENSE ONLY (YEARS)							

Annex 4. Auditorium Overhead Can LED Lamps Data, Assumptions and Analysis.

SCHOOL LIGHT REDUCTION				
DRUMMOND K-12				
APPLICATION				
REPLACE 200 WATT INCANDESCENT DIMMABLE CAN LIGHTS WITH EQUIVALENT OUTPUT LED REFLECTOR FLOODS				
		EXISTING	LED	REDUCTION
LAMP WATTAGE	200		45	155
# LAMPS	25		25	
TYPE	INC		LED	
EST ANNUAL HRS	1000		1000	0
EST AVE USAGE	0.75		0.75	
EST AVE DEMAND	3.75		0.84	3
EST ANNUAL KWH	3750		843.75	2906
ON PEAK RATE	\$ 0.075		\$ 0.075	
OFF PEAK RATE	\$ 0.045		\$ 0.045	
ON PEAK %	70%		70%	
EFFECTIVE RATE	\$ 0.066		\$ 0.066	
EST ANNUAL	\$247.50		\$ 55.69	\$191.81
ENERGY EXP				
MO DEMAND RATE	\$ 11.00		\$ 11.00	
EST MO DEMAND	0.2		0.2	
COINCIDENCE				
EST ANNUAL	\$ 99.00		\$ 22.28	\$ 76.73
MO DEMAND CH.				
DIST DEMAND RATE	\$ 1.25		\$ 1.25	
ANNUAL DIST	0.1		0.1	
DEMAND COIN.				
EST ANNUAL	\$ 5.63		\$ 1.27	\$ 4.36
DIST DEMAND				
EXPENSE				
EST TOTAL POWER				
AND ENERGY	\$352.13		\$ 79.23	\$ 273
EXPENSE				
INVESTMENT PER LAMP			\$ 24.00	
TOTAL INVESTMENT			\$ 600.00	
SIMPLE PAYBACK (YEARS)			2.2	

Annex 5. Auditorium Side Mount Flood LED Lamps Data, Assumptions and Analysis.

SCHOOL LIGHT REDUCTION				
DRUMMOND K-12				
APPLICATION				
REPLACE 200 WATT 100WATT WATT FLOOD LAMPS(SIDE MOUNT) WITH EQUIVALENT OUTPUT LED				
FLOODS				
		EXISTING	LED	REDUCTION
LAMP WATTAGE		100	15	85
# LAMPS		26	15	
TYPE		INC	LED	
EST ANNUA LHRS		1500	1500	0
EST AVE USAGE		100%	100%	
EST AVE DEMAND		2.6	0.23	2.38
(KW				
EST ANNUAL KWH		3900	338	3563
ON PEAK RATE		\$ 0.075	\$ 0.075	
OFF PEAK RATE		\$ 0.045	\$ 0.045	
ON PEAK %		70%	70%	
EFFECTIVE RATE		\$ 0.066	\$ 0.066	
EST ANNUAL		\$257.40	\$ 22.28	\$ 235.13
ENERGY EXP				
MO DEMAND RATE		\$ 11.00	\$ 11.00	
EST MO DEMAND		0.25	0.25	
COINCIDENCE				
EST ANNUAL		\$ 85.80	\$ 7.43	\$ 78.38
MO DEMAND CH.				
DIST DEMAND RATE		\$ 1.25	\$ 1.25	
ANNUAL DIST		0.1	0.1	
DEMAND COIN.				
EST ANNUAL		\$ 3.90	\$ 0.34	\$ 3.56
DIST DEMAND				
EXPENSE				
EST TOTAL POWER				
AND ENERGY		\$347.10	\$ 30.04	\$ 317.06
EXPENSE				
INVESTMENT PER LAMP			\$ 5.00	
TOTAL INVESTMENT			\$ 75.00	
SIMPLE PAYBACK	(YEARS)		0.2	

SCHOOL ENERGY ASSESSMENT			R DREVLLOW		
DRUMMOND K12		MAY	2019		
ADJUST HOT WATER HEATING CIRC PUMP CONTROL					
EXISTING CONTROL			APPEARS TO BE DIFFERENTIAL PRESSURE AT HEAD END		
PROPOSED CONTROL			SEQUENTIALLY REMOTE PRES! PLUS ON OCC AND UNOCC WWSD AND UNOCC SETBACK		
SYSTEM	EXISTING PUMPS	TOTAL	PROPOSED		
NUMBER	1 2	2	1 2	2	
AMPS	28 12	40	15 15	30	
VOLTS	208 208		208 208		
POWER	10.1 4.3	14.4	5403.84 5403.84	10807.68	
ANNUAL OPERATING HOURS	5000 5000	5000	4000 4000	4000	
ANNUAL EFFECTIVE LOAD FACTOR		0.9		0.6	
ANNUAL EFFECTIVE LOAD KW		13.0		9 4.0	
ANNUAL KWH		64846		36000	
ON PEAK ENERGY RATE		0.075		0.075	
OFF PEAK ENERGY RATE		0.045		0.045	
ON PEAK %		70%		\$ 0.60	
EFFECTIVE RATE		\$ 0.066		\$ 0.063	
EST ANNUAL ENERGY EXPENSE		\$ 4,280		\$ 2,268.0 \$ 2,012	
MO DEMAND CH		\$ 11.00		11	
ANNUAL MO DEMAND COINCIDENCE FACTOR		0.6		0.4	
ESTIMATED ANNUAL DEMAND CH		\$ 1,027		\$ 475.20 \$ 552	
MO. DIST . DEMAND CH.		\$ 1.25		\$ 1.25	
EST. DIST CHARGE COINCIDENCE FACTOR		150%		150%	
EST ANNUAL DIST DEMAND CH		\$ 291.81		\$ 202.50 \$ 89	
TOTAL POWER AND ENERGY REDUCTION				\$ 2,653	
COST TO IMPLEMENT			\$ 5,000		
SIMPLE PAYBACK(YEARS)			1.9		
NOTES					
SYSTEM CURRENTLY IS REPORTED TO SERVE BOTH 2 WAY AND 3 WAY VALVES.					
THESE VALVES RESPOND DIFFERENTLY TO CONTROL STRATEGY .					
A- 3 WAY VALVES BYPASS FLOW I.E CAUSE UNNECESSARY FLOW AND REQUIRED POWER AT LOW LOAD PERIODS.					
2 WAY VALVES LIMIT FLOW WHICH RAISES RESISTANCE AND ELEVATES PRESSURE AND POWER REQUIREMENTS IN LOW LOAD PERIODS.					
FINDING A COMPROMISE THAT IS EFFECTIVE OVER THE FULL RANGE OF OPERATING I REQUIERES SOME OPBERVATIONS AND EXPERIMENTATIONS.					
ALTERNATIVES					
ALTERNATIVE SELECTION REQUIRES ASSESSMENT OF TYPES AND NUMBERS OF CONTROL VALVES OF EACH TYPE.					
1. IMPLEMENT AND TUNE A COMPROMISE REMOTE PRESSURE BASED CONTROL UNOCCUPIED RESET AND OCC AND UNOCC WWSD.					
2. CONVERT EXISTING 3 WAY TO 2 WAY VALVES					
3. LOCK 3 WAY VALVE BYPASSES CLOSED TO CREATE 2 WAY VALVES AND REGULATE REMOTE END PRESSURE.					

Annex 7. Auditorium Air Handler, Data, Assumptions and Analysis.

SCHOOL ENERGY ASSESSMENT				R DREVLOW				
	DRUMMOND K-12		13-May	2019				
SCENARIO								
THE SCHOOL AUDITORIUM IS SERVED BY A 15 000 CFM AIR HANDLER								
THE UNIT IS REPORTED AS CURRENTLY OPERATING IN A AN UNOCCUPIED TEMP MAINTENANCE MODE.								
THE LARGE FAN OPERATING INTERMITTENTLY CREATES LARGE LOAD SURGES TO THE BOILER AND PUMPING SYSTEMS.								
THESE CREATE EXCESSIVE BOILER PUMP LOADS AND BOILER LOAD SWINGS WHICH COMPROMISE OPTIMUM OPERATION.								
STEADY STATE LOW FLOW /SPEED/POWER WOULD REDUCE POWER AND ENERGY BILLS AND IMPROVE ENERGY								
PERFORMANCE OF BOILER AND CIRC PUMP SYSTEMS .								
A VFD AND APPROPRIATE CONTROL WILL BE REQUIRED TO ACCOMPLISH THE REDUCTION POTENTIAL .								
THE CURRENT FAN CAPACITY IS LIKELY BASED ON SYSTEM COOLING REQUIREMENT AND LIKELY TWICE THE PEAK								
REQUIREMENT. HEATING REQUIREMENT AND LIKELY 3-4 TIMES AVERAGE HEATING LOAD								
THIS SUGGESTS A SIGNIFICANT POWER AND ENERGY REDUCTION POTENTIAL FOR ALL HEATING CONDITIONS								
GIVEN THE COOLING LOAD COINCIDENCE A SIGNIFICANT COOLING LOAD REDUCTION IS ALSO ANTICIPATED .								
COOLING LOAD FAN REDUCTIONS WOULD NEED TO BE COMPATIBLE TO COOLING SOURCE APPLICATIONS.								
		CURRENT		PROPOSED				
FAN RATING (CFM)		15000		15000				
MOTOR H.P		20						
EFF		0.9						
POWER FACTOR		0.87						
LOAD AT RATED CONDITION		14.4 KW						
CURRENT MOTOR		40						
AMPS								
OPERATING MOTOR P.F.		0.87						
EFFECTIVE MOTOR POWER		12.5 KW		5 KW		7.5		
CURRENT OP CONDITION		87%		35%				
ANNUAL OPERATING HRS		3000		4000				
ESTIMATED ANNUAL		37611 KWH		20000		17611		
ENERGY USE								
ON PEAK ENERGY		0.075						
OFF PEAK ENERGY		0.045						
% ON PEAK		75%		75%				
EFFECTIVE ENERGY RATE		\$ 0.068		\$ 0.068				
EST ANNUAL ENERGY EXPEN		\$ 2,539		\$ 1,350		\$ 1,189		
MO DEMAND RATE		11		11				
MO COINCIDENCE FACTOR		0.5		0.9				
ESTIMATED ANNUAL		\$ 827		594		\$ 233		
MO DEMAND CHARGES								
DIST DEMAND RATE		\$ 1.25		1.25				
ANNUAL DIST. DEMAND								
COINCIDENCE FACTOR		0.6		0.9				
EST. ANN. DIST DEMAND		\$ 113		\$ 68		\$ 45		
EXPENSE								
TOTAL EST ANN.POWE AND ENERGY								
EXPENSE		\$ 3,479		\$ 2,012		\$ 1,467		
ESTIMATED VFD AND CONTROL		\$ 7,000						
IMPLEMENTATION EXPENSE								
ESTIMATED SIMPLE PAYBACK			4.8 YEARS					

Annex 8. Four Small Air Handler VFDS Control, Data, Assumptions and Analysis.

SCHOOL ENERGY ASSESSMENT			R DREVLW					
FACILITY		DRUMMOND K12		13-May				
ENERGY REDUCTION OPPORTUNITY								
THE FACILITY HAS 4 SMALL PNEUMATICALLY CONTROLLED AIR HANDLERS.								
THE PNEUMATIC CONTROL PROVIDES A CONSTANT VOLUME AIR SUPPLY FOR THE ROOMS/ZONES								
BASED ON THE MAXIMUM COOLING LOAD LIKELY TO BE 6 ACH OR MORE.								
CONTINOUS OPERATION IS REQUIRED FOR ALL OPERATING HOURS TO PROVIDE VENTILATION.								
TYPICAL HEATING LOADS CAN NORMALLY BE ACCOMPLISHED WITH 2 TO 3 ACH .								
THE SIGNIFICANT FAN SPEED /AIR FLOW REDUCTION WILL ALLOW SIGNIFICANT FAN POWER REDUCTIONS								
FOR ALL HEATING AND MOST COOLING LOAD PERIODS.								
VFDS AND DIGITAL CONTROL WILL BE REQUIRED TO ACCOMPLISH THE DESIRED POWER AND ENERGY REDUCTIONS.								
CURRENTLY THE FACILITY DOES NOT HAVE MATASYS CONTROL CAPABILITY FOR THE AIR HANDLERS REFERENCED.								
REDUCTION OF THE TOTAL FAN FLOW ALSO REQUIRED ADJUSTMENT OF THE OUTSIDE AIR FLOW DAMPER SYSTEM								
TO MAINTAIN ADEQUATE OUTSIDE AIR WITH A VARIABLE SUPPLY FLOW. THIS IS POSSIBLE WITH DDC								
CONTROL BUT DIFFICULT IF PROBLEMATIC TO ACCOMPLISH WITH PNEUMATIC CONTROL.								
	EXISTING			PROPOSED				
AIR HANDLERS	4			4				
MOTOR H.P	7.5			7.5				
MNOR EFF	0.85			0.85				
POWER FACTOR	8			0.8				
RATED POWER	6.58235							
	EXISTING							
EFFECTIVE /EQUIVALENT								
OPERATING LOAD	90%			0.6				
				0.3				
EST OPERATING LO.	5.92 KW							
EST OPERATING LOAD OUTPU	5.0 KW			1.97 KW			3.1 KW	
EST ANNUAL OPERATING	3500							
HOURS								
EST ANNUAL ENERGY INPUT	82938			27646			55292	
EST EFFECTIVE ENERGY COST	0.065							
	\$ 5,391			\$ 1,797			\$ 3,594	
MO DEMAND RATE	\$ 11.00			\$ 11.00				
MO COINCIDENCE	0.75			0.85				
ESTIMATED ANN. DEMAND	\$ 586.49			\$221.56			\$ 365	
DIST DEMAND	1.25			1.25				
EST ANN DIST. DEMAND	\$ 320			\$ 178			\$ 142	
EST COINC	0.9			1.5				
TOTAL POWER AND							\$ 4,101	
ENERGY REDUCTION								
COST TO IMPLEMENT VFS AND CONTROLS ONTO A FUNCTIONING DDC SYSTEM FOR THE AIR HANDLERS								
				\$ 12,000.00				
SIMPLE PAYBACK				2.9 YEARS				

Annex 9. Repairing Trane UniVents, Data, Assumptions and Analysis.

SCHOOL ENERGY ASSESSMENT			R DREVLOW		
FACILITY		DRUMMOND K12		13-May	
ENERGY REDUCTION OPPORTUNITY					
MULTIPLE CLASSROOMS ARE SERVED BY TRANE UNIVENTS .					
THE UNIVENTS ARE DESCRIBED AS HAVING VARIABLE SPEED FAN MOTORS.					
IT IS ALSO REPORTED THAT A NUMBER OF THE UNITS NO LONGER OPERATE AS					
VARIABLE SPEED UNITS AND ARE EITHER FULL SPEED ON OR OFF. OPERATING					
AT FULL SPEED AND CYCLING IS LESS EFFICIENT THAN OPERATING IN A					
MODULATING FASHION.					
FULL SPEED OPERATION WILL ONLY BE REQUIRED IN WARMUP MODE AND					
MAX COOLING PERIODS.					
MOTORS					
TYPE		VARIABLE SPEED			
NUMBER		12			
HP.		0.5			
EFF		0.8			
FULL SPD		0.46625 KW			
POWER IN					
COINCIDENCE		0.6			
FACTOR					
EST COINCIDENT		3.357 KW			
LOAD					
ANNUAL OPERATING		2500			
HOURS					
EST ANNUAL ENERGY		8393 KWH			
EFF ENERGY RATE		\$ 0.066			
EST ANNUAL ENERGY EXPENSE		\$ 554			
MO DEMAND RATE		\$ 11.00			
DEMAND COINCIDENCE		0.7			
EST ANNUAL DEMAND		\$310.19			
DIST DEMAND RATE		\$ 1.25			
COINCIDENCE		0.8			
EST ANNUAL DIST DEMAND		\$ 40			
EST TOTAL POWER AND ENERGY EXPENSE		\$ 904			
ESTIMATED POWER AND ENERGY REDUCTION POTENTIAL OF					
EFFECTIVE MODULATING FAN OPERATION				50%	
				\$ 452.19	
EST EXPENSE TO REPAIR				\$ 500.00 PER UNIT	
EST TOTAL REPAIE COST				\$ 6,000.00	
SIMPLE PAYBACK				13.3 YEARS	